



Town of Lake Placid

ANNOUNCEMENT OF RFP/RECEIVING OF BIDS

LP-2018-03 Magnolia Generator

RFP NUMBER AND TITLE

Utilities

TOWN DEPARTMENT

Furnish and Install new Kohler Model 250REOZJE at Magnolia Water Treatment Plant. Please see Invitation to Bid and Project Specifications for further details. Can be obtained from Town of Lake Placid Utilities Dept.

DESCRIPTION BRIEF OF PRODUCT OR SERVICE

5/31/2018 @ 12:00 PM

DATE OPEN

6/28/2018 @ 2:00 PM

DATE CLOSED

Utility Director

DEPARTMENT HEAD AUTHORIZATION

INVITATION TO BID

Project #LP-2018-03

The Town of Lake Placid, Highlands County, Lake Placid, Florida, will receive sealed bids at the Town Hall Office of Joe Barber, Director of Utilities, located at 311 W. Interlake Blvd, Lake Placid, Florida 33852 for:

One New KOHLER Model 250REOZJE, EPA Certified Diesel Generator Set

250kW, @ 0.8 PF, 60 Hz, 3 Phase, UL 2200, 277/480 Volt

Specifications may be received at the Town of Lake Placid Municipal Building, 311 W. Interlake Blvd, Lake Placid, Florida 33852, attention, Joe Barber, Director of Utilities. Phone: 863-699-3747

This bid is to supply and install a new generator. Installation must be turn key. Bids should include option to install new fuel tank less than 550 gallons or use existing fuel tank. Bids should include removal of old generator to be placed on a town owned flatbed trailer. Generator will be wired to existing transfer switch. Aluminum roof over existing generator will need to be removed than the re-placed over new generator. Address of generator install is 101 N. Magnolia Avenue, Lake Placid, FL.

Bid envelopes must be sealed and marked, on the outside, with the project name so as to identify the enclosed bids. Bids must be delivered to the Town of Lake Placid at the Town Hall office of Joe Barber, Utility Director, located at 311 W. Interlake Blvd, Lake Placid, Florida 33852 so as to reach said office no later than 2:00 P.M., Thursday June 28, 2018, at which time the bids will be opened. Bids received later than the date and time as specified will be rejected. The Town will not be responsible for the late deliveries of bids that are incorrectly addressed, delivered in person, by mail or any other type of delivery service.

The town of Lake Placid reserves the right to accept or reject any or all bids and to waive any irregularities in bidding.

**Joe Barber
Director of Utilities
Town of Lake Placid**

Printed in the News-Sun Newspaper and advertised on town website.

TOWN OF LAKE PLACID GENERATOR BID SPECIFICATOINS
MAGNOLIA WATER TREATMENT PLANT 5-31-2018
Project #LP-2018-03

One New KOHLER Model 250REOZJE, EPA Certified Diesel Generator Set
250kW, @ 0.8 PF, 60 Hz, 3 Phase, UL 2200, 277/480 Volt

CONTROLLER:
DEC3000

Controller meets NFPA 110

ENCLOSURE:

Sound/Aluminum
181 MPH Wind Load Rated
Critical Silencer

COOLING:

Unit Mounted Radiator
Block Heater 240 Volt, 2500 Watt

FUEL SYSTEM:

Flexible Fuel Lines

GENERATOR ACCESSORIES (Electrical):

Line Circuit Breaker, 3 Pole, 100%, LSI,
Amps: 400 with Shunt Trip

ENGINE ELECTRICAL ACCESSORIES:

Battery Rack and Cables
Starting Battery, Lead Acid
Battery Charger: 6 Amps

CONTROLLER ACCESSORIES LOOSE:

Remote Emergency Stop, Break Glass
Remote Annunciator Panel

ADDITIONAL ACCESSORIES TO BE SUPPLIED:

Certified Factory Test @ 0.8 P.F.
1 Engine, Generator Parts, Maintenance Manuals
1 Electronic Manual
Vibration Isolators: Internal
1 Year Standard Warranty
Initial Start Up and Check Out of System
On Site Testing (Load Bank)

Additional to be SUPPLIED

Off-loading @ Job Site
Installation of System
Supply of Fuel
Fuel & Electrical Piping
All Infrared, 3rd Party and NETA Testing by Others

ADDITIONAL OPTIONS:

ADDER OPTION TO BE SUPPLIED:

Sub-base Fuel Tank, 24 Hour, maximum 549
Gallon, UL142

LEAD TIME:

Must be less than 25 weeks

F.O.B. FACTORY, FREIGHT ALLOWED TO JOB SITE.